



Republic of the Philippines
OFFICE OF THE OMBUDSMAN
Agham Road, Diliman, Quezon City 1104


SUPPLEMENTAL/ BID BULLETIN NO. 2
RE: PUBLIC BIDDING FOR THE CONSTRUCTION OF THREE-STOREY
WITH COVERED ROOF DECK OFFICE BUILDING FOR THE OFFICE OF THE
OMBUDSMAN-MINDANAO AT EARTH CORNER LIBRA STREETS, GISIS HEIGHTS
MATINA, DAVAO CITY

All prospective bidders are hereby advised of the following:

1. The bid proposal shall be in a lump sum amount supported by the Bill of Quantities (BOQ) and Detailed Unit Price Analysis (DUPA). Items which are not included in the BOQ or DUPA but deemed necessary should be categorized/included as **Other Items/Works**.
2. The Procuring Entity, through the Office of the Deputy Ombudsman for Mindanao, will apply for the Building Permit to be assisted by the Contractor and the Consultant. All necessary fees will be shouldered by the Office of the Ombudsman except for those identified in the Bidding Documents/DUPA.
3. For the electrical works of the Project:
 - 3.1. The size of cable tray for CCTV System is 200mm x 50mm, referred to in the Plan/Drawings as Horizontal Cable Tray.
 - 3.2. The **Contractor** shall provide complete IP CCTV System including, among others, 10 KVA UPS, wiring, accessories, devices, equipment and software which include video analysis as may be deemed necessary for a successful operation of the system.
 - 3.3. The Structured Cabling and CCTV System may share in one tray but a **barrier** must be provided.
 - 3.4. Please refer to the DUPA as to the size of conduit per zone for background music/public address system.
 - 3.5. The Voltage Transformer will be provided by the Procuring Entity.
 - 3.6. Please refer to the DUPA (32mmPVC) for the Lightning Arrester or Lightning Protector.

For further inquiries, please coordinate with the Special Bids and Awards Committee (SBAC) Secretariat at Tel. No. 926-53-21 or Trunk Line 479-7300 Local 1332 or 1329.

Please be guided accordingly.


CYRILLE E. RAMOS
Deputy Ombudsman for MOLEO
Chairperson, Special Bids and Awards Committee

HR 11/16/15