



Republic of the Philippines
Office of the Ombudsman
 MINDANAO

Corner Earth and Libra Streets, GSIS Heights, Matina, Davao City
 Website: www.ombudsman.gov.ph/www.philgeps.net.ph

REQUEST FOR QUOTATION

The Office of the Ombudsman – Mindanao Office, through its Bids and Awards Committee (BAC), as duly authorized to conduct Small Value Procurement/Shopping in accordance with Sections 53.9 and 52 of the 2016 Revised Implementing Rules and Regulations of Republic Act No. 9184, hereby invites all interested suppliers/bidders to offer their lowest government price.

Supplier:	Quotation No: 2019-103 NOVEMBER
Address:	PR No: 19-11-154, dated 12 November 2019
	Remarks: 1st Canvass
Tel. No.	Date: November 15, 2019

ATTY. MARIA ILUMINADA S. LAPID-VIVA
 Chairperson, Bids and Awards Committee,
 Office of the Deputy Ombudsman for Mindanao
 Earth corner Libra Streets, GSIS Heights,
 Matina, Davao City

Dear Sir/Madam:

After having carefully read and accepted the Terms and Conditions of this RFQ and followed the Instructions to Bidders specified in Annex B, hereunder is our quotation/s for the item/s as follows:

Item No.	ABC (PhP.)	Qty./Unit	OMB-MIN SPECIFICATIONS		UNIT PRICE	TOTAL PRICE
1	₱ 300,000.00	1 Lot	Labor and materials for the installation of Pressure Sustaining Valve (PSV) Assembly with the following Technical Specifications for the Office of the Ombudsman-Mindanao Office, GSIS Heights, Matina, Davao City Please see attached specifications	<input type="checkbox"/> Comply		

In compliance with GPPB Resolution No. 30-2017, a warranty retention money equivalent to the following shall be imposed:

- 1% for Expendable Supplies and to be release after 3 months period;
 3% for Non-expendable Supplies and to be release after 1 year period


Deadline of Submission: _____ TOTAL PRICE: _____

*Important matters/General Terms and Conditions please see at the back

 SUPPLIER'S REPRESENTATIVE
 (Printed Name)

BY THE AUTHORITY OF THE
 BIDS AND AWARDS COMMITTEE

 Signature/Date


 ARIZONA MARTIN J. BOISER
 AGIO III/Head, BAC Secretariat

Note:

Please state your PhilGeps Number: _____

Canvassed by: _____

Date: _____

ITEM	SPECIFICATIONS	
50mmØ Pressure Sustaining Valve	Body	Ductile Iron
	Flange and Thickness	ANSI/ASME Standard/ISO
	Stem	Stainless Steel
	Seat	Bronze/Stainless Steel
	Pilot	Bronze/Stainless Steel
	Diaphragm	Nylon Reinforce (BUNA-N)/ EPDM
	Spring	Stainless Steel
	Tubing	Copper/Flexible Hose
	Internal and External coating	Electrostatically applied or fusion bonded epoxy powder/Rilsan
	Controls: Fittings and control devices	Bronze/Stainless Steel
	Rated Working Pressure	200 psi
50mmØ Gate Valve	Body and Bonnet	Ductile Iron
	Flange and Thickness	ANSI/ASME Standard/ISO
	Stem	Stainless Steel
	Stem Sealing	EPDM (for drinking water)
	Wedge	Ductile Iron, core fully vulcanized with EPDM rubber
	Thrust Collar	Dezincification resistant brass
	Internal and External coating	Electrostatically applied or fusion bonded epoxy powder
	Rated Working Pressure	200 psi
	Gasket (Other Accessories)	EPDM (for drinking water)
	Bolts and Nuts (Other Accessorie)	Hot-dip zinc coated Glvanized Iron
25mmØ Air Release Valve Threaded Type	Threaded Connection	NPT-American Standard Pipe Thread Tape per ANSI/ASME BSPT-British Standard Pipe Threat per ISO
	Material	Cast Iron, Ductile Iron or Reinforced Nylon
	Floats	Stainless Steel, Foamed Polypropylene or Polycarbonate
	O-ring	EPDM (for drinking water)
	Related Working Pressure	200 psi
50mmØ Wye Strainer	Body	Cast Iron
	Flange and Thickness	As per NSI or ISO Standard
	Screen	Stainless Steel (1.50mm perforation)
	Gasket	Rubber (NBR/EPDM)
	Cover	Cast Iron
	Bolts and Nuts	Carbon Steel
	Plug	Carbon Steel
50mmØ Mechanical Sleeve Type Coupling, Universal	Center sleeve and end ring	Ductile Iron
	Bolt and Nuts (Bolt Size-12mmØ)	Hot-dip zinc coated (Glvanized Iron)
	Gasket	EPDM (for drinking water)
	Washer	Hot-dip zinc coated (Glvanized Iron) or sheraplex coated
	Coating	Electrostatically applied or fusion bonded epoxy powder
	Rated Working Pressure	200 psi
	Inside Dia. Pipe tolerance Ranges (Sealing Range) (mm)	57-74
	Min. Center Sleeve Length (mm)	95
50mmØ Check Valve	Type	Wafer
	Body	Cast Iron (ASTM A48 Grade 30)
	Disc	Stainless Steel (ASTM Type 304 Min.)
	Seat	EPDM for drinking water
	Coating (Internal & External)	Electrostatically applied or fusion bonded epoxy
	Rated Working Pressure	200 psi
Pressure Gauge, 19mmØ (3/4")		Oil-Filled
	Maximum Pressure	300 Psi
50mmØ Black Iron (B.I.) Pipe	Schedule 40	
	Wire Mesh Enclosure	2" x 2" Angle bar and 1" x 1" Wire Mesh