

Republic of the Philippines
OFFICE OF THE OMBUDSMAN
Bids and Awards Committee – Central Office
Agham Road, Diliman, Quezon City 1104

SUPPLEMENTAL / BID BULLETIN NO. 1

QN 2020-0034-OCT: “One (1) lot Annual Preventive Maintenance (PM) of existing Fire Suppression System – Main Building and One (1) lot Annual Preventive Maintenance (PM) of existing Fire Suppression System – Annex Building”

**CLARIFICATIONS ON THE TECHNICAL SPECIFICATIONS and
EXTENSION OF DEADLINE OF SUBMISSION OF BIDS**

03 November 2020

A. In response to queries of prospective bidders, the BAC hereby issues the following clarifications on the technical specifications in **QN 2020-0034-OCT**:

1. **Query:** On Annual Preventive Maintenance (PM) of Fire Suppression System at Server Room – Main Building: Refilling for gas within acceptable level, except, in the event of use in legitimate fire incident or accidental dispersal on the site; --- *ibig po bang sabihin incase may accidental discharge sa site, even walang PM services or actual fire na nangyayari. It will be refilled for free?*


It will be refilled for free if the discharge is because of the system problem or issue like leak.

2. **Query:** Accommodate on-call requests for technical support and assistance to immediately address and correct any trouble on the system covered in the maintenance; --- *for the emergency call po ba 24/7. Ang contract po is 1 year for 1 time PMS service only?*

**Yes, 24/7 support. Yes, 1 time PM only but 24/7 support in case of emergency
Answer:**

B. The bidder/supplier offering the lowest calculated bid shall be required to submit the following documentary requirements **within three (3) working days from receipt of notification.**

C. Please be informed that the deadline of submission of bids is extended until **10 November 2020, 12:00 p.m.**


MARIBETH T. PADIO
Assistant Ombudsman, PIEMS
Chairperson, Bids and Awards Committee